



**EMERGENCY CALLED MEETING OF THE COMMISSIONERS COURT  
OF JOHNSON COUNTY  
JOHNSON COUNTY COURTHOUSE, #2 MAIN STREET  
COMMISSIONERS COURTROOM, 2<sup>ND</sup> FLOOR  
CLEBURNE, TEXAS  
THURSDAY, AUGUST 14, 2014-11:00 AM**

---

**I. ACTION**

1. Consideration of County Expenditures Regarding Repair of Lift Station #1 at the Johnson County Jail

---

Roger Harmon, Johnson County Judge

**2-Hour Notice 8-14-2014**

This Agenda Filed at Posting Time by the County Clerk Under the:  
Open Meetings Act *Chapter 551*, Texas Government Code  
Posting Requirement *Section 551.041*, Texas Government Code

Notice of Assistance at Public Meeting: Persons with disabilities who plan to attend this meeting and who may need special assistance or services are requested to contact Alison Hitchcock (817-556-6360) two (2) days prior to the meeting.

Emergency Called Meeting Pursuant to *Section 551.045, Gov. Code* – The retaining wall at Lift Station #1 at the Johnson County Jail is collapsing into the pump making it impossible to remove and clean debris from the pump. Immediate action is needed to correct the situation so that the pump can be removed and cleaned of debris. The debris can completely clog the sewer in Buildings C1 and C2 which will cause the sewer to back-up in the buildings and create an imminent threat to the public health and safety of inmates housed in Buildings C1 and C2. Additionally, the collapse of the retaining wall was an unforeseeable situation.